



Local Government Energy Audit: Energy Audit Report



Copyright ©2019 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Montclair Community Pre-K

22 Valley Road

Montclair, New Jersey 07042

Montclair Board of Education

January 3, 2019

Final Report by:

TRC Energy Services

Disclaimer

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

Table of Contents

1	Executive Summary	1
1.1	Facility Summary	1
1.2	Your Cost Reduction Opportunities.....	2
	Energy Conservation Measures.....	2
	Energy Efficient Practices	3
	On-Site Generation Measures.....	4
1.3	Implementation Planning.....	5
2	Facility Information and Existing Conditions	6
2.1	Project Contacts	6
2.2	General Site Information.....	6
2.3	Building Occupancy	6
2.4	Building Envelope	6
2.5	On-Site Generation.....	7
2.6	Energy-Using Systems	7
	Lighting System	7
	Heating System	8
	Direct Expansion Air Conditioning System (DX)	8
	Domestic Hot Water Heating System.....	9
	Building Plug Load	9
3	Site Energy Use and Costs	10
3.1	Total Cost of Energy	10
3.2	Electricity Usage	11
3.3	Natural Gas Usage	13
3.4	Benchmarking.....	15
3.5	Energy End-Use Breakdown	16
4	Energy Conservation Measures.....	17
4.1	High Priority ECMs.....	17
4.1.1	Lighting Upgrades.....	18
	ECM 1: Install LED Fixtures.....	18
	ECM 2: Retrofit Fixtures with LED Lamps.....	19
4.1.2	Lighting Control Measures	20
	ECM 3: Install Occupancy Sensor Lighting Controls	20
	ECM 4: Install High/Low Lighting Controls	21
4.2	Other Evaluated ECM	22
	Install High Efficiency Air Conditioning Units.....	22
5	Energy Efficient Practices	23
	Perform Proper Lighting Maintenance.....	23
	Develop a Lighting Maintenance Schedule	23
	Clean Evaporator/Condenser Coils on AC Systems.....	23

Clean and/or Replace HVAC Filters	23
Perform Proper Water Heater Maintenance	24
Plug Load Controls.....	24
Water Conservation	24
6 On-Site Generation Measures	25
6.1 Photovoltaic.....	26
6.2 Combined Heat and Power	27
7 Demand Response	28
8 Project Funding / Incentives	29
8.1 SmartStart	30
8.2 SREC Registration Program.....	31
8.3 Energy Savings Improvement Program	32
9 Energy Purchasing and Procurement Strategies	33
9.1 Retail Electric Supply Options.....	33
9.2 Retail Natural Gas Supply Options	33

Appendix A: Equipment Inventory & Recommendations

Appendix B: ENERGY STAR® Statement of Energy Performance

Table of Figures

Figure 1 – Previous 12 Month Utility Costs..... 2

Figure 2 – Potential Post-Implementation Costs 2

Figure 3 – Summary of Energy Reduction Opportunities 3

Figure 4 – Photovoltaic Potential..... 4

Figure 5 – Project Contacts 6

Figure 6 - Building Schedule..... 6

Figure 7 – Building Façade 6

Figure 8 - Building Lighting Systems 7

Figure 9 – Heating System 8

Figure 10 – DX Air Conditioning System 8

Figure 11 – Domestic Water Heater 9

Figure 12 - Utility Summary 10

Figure 13 - Energy Cost Breakdown..... 10

Figure 14 - Electric Usage & Demand..... 11

Figure 15 - Electric Usage & Demand..... 12

Figure 16 - Natural Gas Usage..... 13

Figure 17 - Natural Gas Usage..... 14

Figure 18 - Energy Use Intensity Comparison – Existing Conditions..... 15

Figure 19 - Energy Use Intensity Comparison – Following Installation of Recommended Measures 15

Figure 20 - Energy Balance (% and kBtu/SF) 16

Figure 21 – Summary of High Priority ECMs..... 17

Figure 22 – Summary of Lighting Upgrade ECMs..... 18

Figure 23 – Summary of Lighting Control ECMs 20

Figure 24 – Summary of Other Evaluated ECM 22

Figure 25 - Photovoltaic Screening 26

Figure 26 - ECM Incentive Program Eligibility..... 29

I EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) Report for Montclair Community Pre-K.

The goal of an LGEA report is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and provide information and assistance to help facilities implement ECMs. The LGEA report also contains valuable information on financial incentives from New Jersey's Clean Energy Program (NJCEP) for implementing ECMs.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey educational facilities in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

I.1 Facility Summary

Montclair Community Pre-K is a 28,511 square foot facility constructed in 1900. The building is a three-story educational facility including but not limited to classrooms, offices, hallways and restrooms.

Lighting at the facility consists mainly of 32-Watt T8 linear fluorescent fixtures with 32-Watt T8 U-bend fluorescent fixtures; all of which are inefficient in performance when compared to the latest lighting technology available in the market. In addition to linear fluorescent technology, the facility also has several 60-Watt incandescent lamps. Exterior lighting is provided by a combination of 70-Watt and 100-Watt metal halide fixtures and 150-Watt high pressure sodium fixtures. Interior lighting control is provided by a combination of manual switches and occupancy sensors.

Cooling and ventilation is provided by a combination of package units and window AC units. Heating is provided by the Central Heating Plant.

A thorough description of the facility and our observations are located in Section 2.

I.2 Your Cost Reduction Opportunities

Energy Conservation Measures

TRC evaluated five measures and recommended four measures which together represent an opportunity for Montclair Community Pre-K to reduce annual energy costs by roughly \$7,443 and annual greenhouse gas emissions by 49,167 lbs CO₂e. We estimate that if all high priority measures are implemented as recommended, the project will pay for itself in roughly 5.4 years. TRC has defined high priority measures as the evaluated measures that have a simple payback less than the typical equipment life of the proposed equipment. The breakdown of existing and potential utility costs after project implementation are illustrated in Figure 1 and Figure 2, respectively. Together these measures represent an opportunity to reduce Montclair Community Pre-K's annual energy use by 12%.

Figure 1 – Previous 12 Month Utility Costs





Figure 2 – Potential Post-Implementation Costs



A detailed description of Montclair Community Pre-K's existing energy use can be found in Section 3.

Estimates of the total cost, energy savings, and financial incentives for the evaluated energy efficient upgrades are summarized below in Figure 3. A brief description of each category can be found below and a description of savings opportunities can be found in Section 4.

Figure 3 – Summary of Energy Reduction Opportunities

Energy Conservation Measure		High Priority?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			41,993	11.1	0.0	\$6,401.83	\$33,919.29	\$6,125.00	\$27,794.29	4.3	42,286
ECM 1	Install LED Fixtures	Yes	3,857	0.5	0.0	\$588.01	\$3,125.42	\$800.00	\$2,325.42	4.0	3,884
ECM 2	Retrofit Fixtures with LED Lamps	Yes	38,136	10.6	0.0	\$5,813.83	\$30,793.88	\$5,325.00	\$25,468.88	4.4	38,402
Lighting Control Measures			6,833	1.9	0.0	\$1,041.64	\$13,830.00	\$1,715.00	\$12,115.00	11.6	6,880
ECM 3	Install Occupancy Sensor Lighting Controls	Yes	6,525	1.8	0.0	\$994.77	\$13,230.00	\$1,715.00	\$11,515.00	11.6	6,571
ECM 4	Install High/Low Lighting Controls	Yes	307	0.1	0.0	\$46.87	\$600.00	\$0.00	\$600.00	12.8	310
Electric Unitary HVAC Measures			4,208	3.1	0.0	\$641.58	\$46,537.06	\$996.67	\$45,540.39	71.0	4,238
	Install High Efficiency Electric AC	No	4,208	3.1	0.0	\$641.58	\$46,537.06	\$996.67	\$45,540.39	71.0	4,238
TOTALS FOR HIGH PRIORITY MEASURES			48,825	12.9	0.0	\$7,443.48	\$47,749.29	\$7,840.00	\$39,909.29	5.4	49,167
TOTALS FOR ALL EVALUATED MEASURES			53,034	16.1	0.0	\$8,085.06	\$94,286.35	\$8,836.67	\$85,449.69	10.6	53,405

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Lighting Upgrades generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measures save energy by reducing the power used by the lighting components due to improved electrical efficiency.

Lighting Controls measures generally involve the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

Electric Unitary HVAC measures generally involve replacing older inefficient air conditioning systems with modern energy efficient systems. New air conditioning systems can provide equivalent cooling to older air condition systems at a reduced energy cost. These measures save energy by reducing the power used by the air conditioning systems, due to improved electrical efficiency.

Energy Efficient Practices

TRC also identified seven low cost (or no cost) energy efficient practices. A facility's energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and O&M costs. Potential opportunities identified at Montclair Community Pre-K include:

- Perform Proper Lighting Maintenance
- Develop a Lighting Maintenance Schedule
- Clean Evaporator/Condenser Coils on AC Systems
- Clean and/or Replace HVAC Filters
- Perform Proper Water Heater Maintenance
- Install Plug Load Controls
- Water Conservation

For details on these energy efficient practices, please refer to Section 5.

On-Site Generation Measures

TRC evaluated the potential for installing on-site generation for Montclair Community Pre-K. Based on the configuration of the site and its loads there is a moderate potential for installing a photovoltaic (PV) array.

Figure 4 – Photovoltaic Potential

Potential	Medium	
System Potential	50	kWDC STC
Electric Generation	59,569	kWh/yr
Displaced Cost	\$5,180	/yr
Installed Cost	\$130,000	

For details on our evaluation and on-site generation potential, please refer to Section 6.

I.3 Implementation Planning

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements.

Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- SREC (Solar Renewable Energy Certificate) Registration Program (SRP)
- Energy Savings Improvement Program (ESIP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program you may utilize internal resources, or an outside firm or contractor, to do the final design of the ECM(s) and do the installation. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SmartStart program. More details on this program and others are available in Section 8.

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. An LGEA report (or other approved energy audit) is required for participation in ESIP. Please refer to Section 8.3 for additional information on the ESIP Program.

The Demand Response Energy Aggregator is a (non-NJCEP) program designed to reduce electric loads at commercial facilities, when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. Demand Response (DR) service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability. By enabling grid operators to call upon commercial facilities to reduce their electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and facilities receive payments whether or not they are called upon to curtail their load during times of peak demand. Refer to Section 7 for additional information on this program.

Additional information on relevant incentive programs is located in Section 8 or: www.njcleanenergy.com/ci.

2 FACILITY INFORMATION AND EXISTING CONDITIONS

2.1 Project Contacts

Figure 5 – Project Contacts

Name	Role	E-Mail	Phone #
Customer			
Emidio D'Andrea	Business Administrator	edandrea@montclair.k12.nj.us	(973) 509-4050
John Eschmann	Director of Facilities	jeschmann@montclair.k12.nj.us	(973) 509-4044
Designated Representative			
Matthew Wolchko	Project Architect	mwolchko@planetpsa.com	(973) 586-2400
TRC Energy Services			
Thomas Page	Auditor	MTraore@trcsolutions.com	(732) 855-0033

2.2 General Site Information

On November 09, 2016, TRC performed an energy audit at Montclair Community Pre-K located in Montclair, New Jersey. TRC's team met with John Eschmann to review the facility operations and help focus our investigation on specific energy-using systems.

Montclair Community Pre-K is a 28,511 square foot facility constructed in 1900. The building is a three-story educational facility including but not limited to classrooms, offices, hallways and restrooms.

2.3 Building Occupancy

The typical schedule is presented in the table below.

Figure 6 - Building Schedule

Building Name	Weekday/Weekend	Operating Schedule
Montclair Community Pre-K	Weekday	8:00 AM - 6:00 PM
Montclair Community Pre-K	Weekend	unoccupied

2.4 Building Envelope

The Pre-K facility is a three-story building. The construction is of concrete masonry block with painted exterior and double pane clear windows with operable frames. The slanted roof in the main building is constructed of tile roofing material.

Figure 7 – Building Façade



2.5 On-Site Generation

Montclair Community Pre-K does not have any on-site electric generation capacity.

2.6 Energy-Using Systems


Please see Appendix A: Equipment Inventory & Recommendations for an inventory of the facility's equipment.

Lighting System

Lighting at Montclair Community Pre-K consists mainly of 32-Watt T8 linear fluorescent fixtures with a few 32-Watt T8 U-bend fluorescent fixtures. These sources are inefficient in performance when compared to the latest lighting technology available in the market. The linear fluorescent fixtures are 4-foot long or U-bend, mainly troffers with diffusers having 2, 3, or 4-lamp configurations. In addition to the fluorescent fixtures, the facility is also served by 60-Watt incandescent lamps. All the exit signs are LED fixtures.

Interior lighting control in the building is provided by a combination of manual switches and occupancy sensors.

Figure 8 - Building Lighting Systems




Exterior lighting is provided by a combination of 70-Watt and 100-Watt metal halide fixtures and 150-Watt high pressure sodium fixtures.

Heating System

The Central Heating Plant has two natural gas fired Weil McLain steam boilers with an input rating of 7,938 MBh each and a nominal efficiency of 80%. These boilers provide space heating for Hillside School, the Montclair Community Pre-K, and the district Administration Building.


Figure 9 – Heating System



Direct Expansion Air Conditioning System (DX)

Air conditioning (AC) at the facility is primarily provided by a combination of package units and window AC units. Package/portable units have capacities between 1 ton and 2.67 tons and window AC units have capacities between 0.58 ton and 1.25 tons with efficiency ratings of around 10.9 EER.


Figure 10 – DX Air Conditioning System



Domestic Hot Water Heating System

The domestic hot water heating system for the facility consists of one A.O. Smith gas fired hot water heater with an input rating of 199 kBtu/hr and a nominal efficiency of 80%. The water heater has a 100 gallon storage tank.

Figure 11 – Domestic Water Heater



Building Plug Load

The facility contains several plug-load systems which contribute to plug load electric use including but not limited to copier, printers, microwaves, and refrigerators.

3 SITE ENERGY USE AND COSTS

Utility data for electricity and natural gas was analyzed to identify opportunities for savings. In addition, data for electricity and natural gas was evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. These metrics are an estimate of the relative energy efficiency of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking section within Section 3.4 for additional information.

3.1 Total Cost of Energy


The following energy consumption and cost data is based on the last 12-month period of utility billing data that was provided for each utility. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

Figure 12 - Utility Summary

Utility Summary for Montclair Community Pre-K		
Fuel	Usage	Cost
Electricity	116,830 kWh	\$17,811
Natural Gas	9,397 Therms	\$7,536
Total		\$25,347

The current annual energy cost for this facility is \$25,347 as shown in the chart below.

Figure 13 - Energy Cost Breakdown



3.2 Electricity Usage

Electricity is provided by PSE&G. The average electric cost over the past 12 months was \$0.152/kWh, which is the blended rate that includes energy supply, distribution, and other charges. This rate is used throughout the analyses in this report to assess energy costs and savings. The monthly electricity consumption and peak demand are shown in the chart below.

Electric usage estimation and calibration methodology:

1. The Montclair BOE buildings Hillside School, Administration, Montclair Community Pre-K, and Central Heating Plant are served by three electric meters 65 795 083 02, 67 125 896 06, and 42 007 763 08. There is not a clear delineation of loads served by the meters. Based on this, demand (kW) data was not prorated.
2. Total energy use from all the meters combined is around 638,475 kWh for a 12-month period.
3. Monthly “calculated” energy use from the LGEA analysis tools were used to calculate the percentage contribution of each building. The percentages are:
 - a. Hillside School – 70%
 - b. Administration Building – 11%
 - c. Montclair Community Pre-K – 18%
 - d. Central Heating Plant – 1%
4. The above percentages were applied to the “actual” total monthly energy use from bills to estimate monthly utility energy use to which all the tools were then calibrated.

Figure 14 - Electric Usage & Demand




Figure 15 - Electric Usage & Demand

Electric Billing Data for Montclair Community Pre-K				
Period Ending	Days in Period	Electric Usage (kWh)	Total Electric Cost	TRC Estimated Usage?
6/15/15	33	10,375	\$2,017	Yes
7/14/15	29	9,253	\$1,779	Yes
8/12/15	29	8,183	\$1,563	Yes
9/14/15	33	9,947	\$1,826	Yes
10/13/15	29	9,930	\$1,466	Yes
11/10/15	28	9,217	\$1,296	Yes
12/11/15	31	10,753	\$1,474	Yes
1/13/16	33	9,531	\$1,245	Yes
2/11/16	29	11,228	\$1,442	Yes
3/14/16	32	10,498	\$1,348	Yes
4/13/16	30	9,349	\$1,257	Yes
5/13/16	30	8,885	\$1,148	Yes
Totals	366	117,150	\$17,860	12
Annual	365	116,830	\$17,811	

3.3 Natural Gas Usage

Natural gas is provided by PSE&G. The average gas cost for the past 12 months is \$0.802/therm, which is the blended rate used throughout the analyses in this report. The monthly gas consumption is shown in the chart below.

Natural gas use was allocated to the sites served by the Central Heating Plant using the following method:

1. The Administration Building, Hillside School, Montclair Community Pre-K, and Central Heating Plant are served by two gas meters: 65 795 083 02 and 67 125 896 06. There is not a clear delineation of which buildings and equipment are served by each meter.
2. Total annual gas use for both of the meters combined is 59,235 therms.
3. The calculated gas use from the LGEA analysis for each building was used to determine the percentage of the total historical gas use to be assigned to each building. Total gas use was allocated to the three buildings served by the Central Heating Plant as follows:
 - a. Hillside School - 75%
 - b. Administration Building - 9%
 - c. Montclair Community Pre-K - 16%
4. The above percentages were applied to the total monthly gas use from the utility bills to estimate the monthly gas use for the individual buildings. This estimated monthly gas use is what is provided in each of the reports.

Figure 16 - Natural Gas Usage




Figure 17 - Natural Gas Usage

Gas Billing Data for Montclair Community Pre-K				
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost	TRC Estimated Usage?
6/15/15	33	1,253	\$676	Yes
7/14/15	29	106	\$212	Yes
8/12/15	29	89	\$88	Yes
9/14/15	33	89	\$220	Yes
10/13/15	29	97	\$136	Yes
11/10/15	28	143	\$152	Yes
12/11/15	31	153	\$198	Yes
1/13/16	33	2,174	\$2,036	Yes
2/11/16	29	2,113	\$1,938	Yes
3/14/16	32	1,202	\$819	Yes
4/13/16	30	823	\$447	Yes
5/13/16	30	1,181	\$634	Yes
Totals	366	9,423	\$7,556	12
Annual	365	9,397	\$7,536	

3.4 Benchmarking

This facility was benchmarked using Portfolio Manager®, an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR® program. Portfolio Manager® analyzes your building’s consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR® score for select building types.

The EUI is a measure of a facility’s energy consumption per square foot, and it is the standard metric for comparing buildings’ energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of “site energy” and “source energy.” Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

Figure 18 - Energy Use Intensity Comparison – Existing Conditions

Energy Use Intensity Comparison - Existing Conditions		
	Montclair Community Pre-K	National Median Building Type: School (K-12)
Source Energy Use Intensity (kBtu/ft ²)	78.5	141.4
Site Energy Use Intensity (kBtu/ft ²)	46.9	58.2

Implementation of all recommended measures in this report would improve the building’s estimated EUI significantly, as shown in the table below:

Figure 19 - Energy Use Intensity Comparison – Following Installation of Recommended Measures

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Montclair Community Pre-K	National Median Building Type: School (K-12)
Source Energy Use Intensity (kBtu/ft ²)	60.2	141.4
Site Energy Use Intensity (kBtu/ft ²)	41.1	58.2

Many types of commercial buildings are also eligible to receive an ENERGY STAR® score. This score is a percentile ranking from 1 to 100. It compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75 percent of all similar buildings nationwide and may be eligible for ENERGY STAR® certification. The Central Heating Plant and the three buildings served by it have a combined score of 74.

A Portfolio Manager® Statement of Energy Performance (SEP) was generated for this facility, see Appendix B: ENERGY STAR® Statement of Energy Performance.


For more information on ENERGY STAR® certification go to: <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

A Portfolio Manager® account has been created online for your facility and you will be provided with the login information for the account. We encourage you to update your utility information in Portfolio Manager® regularly, so that you can keep track of your building’s performance. Free online training is available to help you use ENERGY STAR® Portfolio Manager® to track your building’s performance at: <https://www.energystar.gov/buildings/training>.

3.5 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed at this facility. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage. This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

Figure 20 - Energy Balance (% and kBtu/SF)



4 ENERGY CONSERVATION MEASURES

Level of Analysis

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the Montclair Community Pre-K regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom SmartStart or Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJCEP prescriptive SmartStart program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

4.1 High Priority ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

Figure 21 – Summary of High Priority ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		41,993	11.1	0.0	\$6,401.83	\$33,919.29	\$6,125.00	\$27,794.29	4.3	42,286
ECM 1	Install LED Fixtures	3,857	0.5	0.0	\$588.01	\$3,125.42	\$800.00	\$2,325.42	4.0	3,884
ECM 2	Retrofit Fixtures with LED Lamps	38,136	10.6	0.0	\$5,813.83	\$30,793.88	\$5,325.00	\$25,468.88	4.4	38,402
Lighting Control Measures		6,833	1.9	0.0	\$1,041.64	\$13,830.00	\$1,715.00	\$12,115.00	11.6	6,880
ECM 3	Install Occupancy Sensor Lighting Controls	6,525	1.8	0.0	\$994.77	\$13,230.00	\$1,715.00	\$11,515.00	11.6	6,571
ECM 4	Install High/Low Lighting Controls	307	0.1	0.0	\$46.87	\$600.00	\$0.00	\$600.00	12.8	310
TOTALS		48,825	12.9	0.0	\$7,443.48	\$47,749.29	\$7,840.00	\$39,909.29	5.4	49,167

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

4.1.1 Lighting Upgrades

Our recommendations for upgrades to existing lighting fixtures are summarized in Figure 22 below.

Figure 22 – Summary of Lighting Upgrade ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Reduction (lbs)
Lighting Upgrades		41,993	11.1	0.0	\$6,401.83	\$33,919.29	\$6,125.00	\$27,794.29	4.3	42,286
ECM 1	Install LED Fixtures	3,857	0.5	0.0	\$588.01	\$3,125.42	\$800.00	\$2,325.42	4.0	3,884
ECM 2	Retrofit Fixtures with LED Lamps	38,136	10.6	0.0	\$5,813.83	\$30,793.88	\$5,325.00	\$25,468.88	4.4	38,402

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 1: Install LED Fixtures

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Exterior	3,857	3,857	0	0.5	0.0	\$588.01	\$3,125.42	\$800.00	\$2,325.42	4.0	3,884

Measure Description

We recommend replacing exterior fixtures containing metal halide and high-pressure sodium lamps with new high-performance LED light fixtures. This measure saves energy by installing LEDs which use less power than other technologies with a comparable light output.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a metal halide or high-pressure sodium lamp.

ECM 2: Retrofit Fixtures with LED Lamps

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Annual Electric Savings (kWh)	Chilled Water Savings (Ton-Hr)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	38,136	38,136	0	10.6	0.0	\$5,813.83	\$30,793.88	\$5,325.00	\$25,468.88	4.4	38,402

Measure Description

We recommend retrofitting existing T8 linear fluorescent, T8 U-bend fluorescent, and incandescent lighting technologies with LED lamps. Many LED tube lamps are direct replacements for existing fluorescent lamps and can be installed while leaving the fluorescent fixture ballast in place. LED bulbs can be used in existing fixtures as a direct replacement for most other lighting technologies. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of fluorescent tubes and more than 10 times longer than many incandescent lamps.

4.1.2 Lighting Control Measures

Our recommendations for lighting control measures are summarized in Figure 23 below.

Figure 23 – Summary of Lighting Control ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures		6,833	1.9	0.0	\$1,041.64	\$13,830.00	\$1,715.00	\$12,115.00	11.6	6,880
ECM 3	Install Occupancy Sensor Lighting Controls	6,525	1.8	0.0	\$994.77	\$13,230.00	\$1,715.00	\$11,515.00	11.6	6,571
ECM 4	Install High/Low Lighting Controls	307	0.1	0.0	\$46.87	\$600.00	\$0.00	\$600.00	12.8	310

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 3: Install Occupancy Sensor Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
6,525	1.8	0.0	\$994.77	\$13,230.00	\$1,715.00	\$11,515.00	11.6	6,571

Measure Description

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches in classrooms, restrooms, offices areas, etc. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

ECM 4: Install High/Low Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
307	0.1	0.0	\$46.87	\$600.00	\$0.00	\$600.00	12.8	310

Measure Description

We recommend installing occupancy sensors to provide dual level lighting control for lighting fixtures in spaces that are infrequently occupied but may require some level of continuous lighting for safety or security reasons. Typical areas for such lighting control are stairwells, interior corridors, parking lots, and parking garages.

Lighting fixtures with these controls operate at default low levels when the area is not occupied to provide minimal lighting to meet security or safety requirements. Sensors detect occupancy using ultrasonic and/or infrared sensors. The lighting systems are switched to full lighting levels whenever an occupant is detected. Fixtures are automatically switched back to low level after an area has been vacant for a preset period of time. Energy savings results from only providing full lighting levels when it is required.

For this type of measure the occupancy sensors will generally be ceiling or fixture mounted. Sufficient sensor coverage needs to be provided to ensure that lights turn on in each area as an occupant approaches.

Additional savings from reduced lighting maintenance may also result from this measure, due to reduced lamp operation.

4.2 Other Evaluated ECM

The measure below has been evaluated by the auditor but are not recommended for implementation at the facility. Reasons for exclusion can be found in the measure description section.

Figure 24 – Summary of Other Evaluated ECM

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Electric Unitary HVAC Measures	4,208	3.1	0.0	\$641.58	\$46,537.06	\$996.67	\$45,540.39	71.0	4,238
Install High Efficiency Electric AC	4,208	3.1	0.0	\$641.58	\$46,537.06	\$996.67	\$45,540.39	71.0	4,238
TOTALS	4,208	3.1	0.0	\$641.58	\$46,537.06	\$996.67	\$45,540.39	71.0	4,238

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Install High Efficiency Air Conditioning Units

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
4,208	3.1	0.0	\$641.58	\$46,537.06	\$996.67	\$45,540.39	71.0	4,238

Measure Description

We recommend replacing standard efficiency packaged air conditioning units with high efficiency packaged air conditioning units when cost effective. There have been significant improvements in both compressor and fan motor efficiencies over the past several years. Therefore, electricity savings can be achieved by replacing older units with new high efficiency units. A higher EER or SEER rating indicates a more efficient cooling system. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average cooling load, and the estimated annual operating hours.

Reasons for not Recommending

This measure has a long payback, more than the rated useful life of the replacement equipment. The measure is not recommended for implementation on the basis of energy savings alone.

5 ENERGY EFFICIENT PRACTICES

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

Perform Proper Lighting Maintenance

In order to sustain optimal lighting levels, lighting fixtures should undergo routine maintenance. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust on lamps, fixtures and reflective surfaces. Together, these factors can reduce total illumination by 20% - 60% or more, while operating fixtures continue drawing full power. To limit this reduction, lamps, reflectors and diffusers should be thoroughly cleaned of dirt, dust, oil, and smoke film buildup approximately every 6 – 12 months.

Develop a Lighting Maintenance Schedule

In addition to routine fixture cleaning, development of a maintenance schedule can both ensure maintenance is performed regularly and can reduce the overall cost of fixture re-lamping and re-ballasting. By re-lamping and re-ballasting fixtures in groups, lighting levels are better maintained and the number of site visits by a lighting technician or contractor can be minimized, decreasing the overall cost of maintenance.

Clean Evaporator/Condenser Coils on AC Systems

Dirty evaporators and condensers coils cause a restriction to air flow and restrict heat transfer. This results in increased evaporator and condenser fan load and a decrease in cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

Clean and/or Replace HVAC Filters

Air filters work to reduce the amount of indoor air pollution and increase occupant comfort. Over time, filters become less and less effective as particulate buildup increases. In addition to health concerns related to clogged filters, filters that have reached saturation also restrict air flow through the facility's air conditioning or heat pump system, increasing the load on the distribution fans and decreasing occupant comfort levels. Filters should be checked monthly and cleaned or replaced when appropriate.

Perform Proper Water Heater Maintenance

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

Plug Load Controls

There are a variety of ways to limit the energy use of plug loads including increasing occupant awareness, removing under-utilized equipment, installing hardware controls, and using software controls. Some control steps to take are to enable the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips. For additional information refer to “Plug Load Best Practices Guide” <http://www.advancedbuildings.net/plug-load-best-practices-guide-offices>.

Water Conservation

Installing low-flow faucets or faucet aerators, low-flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gallons per minute (gpm) for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low-flow toilets and low-flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gallons per flush (gpf) and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

6 ON-SITE GENERATION MEASURES

On-site generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey's Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State's electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.


6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility’s electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility’s electric demand, size and location of free area, and shading elements shows that the facility has a **Medium** potential for installing a PV array.

The amount of free area, ease of installation (location), and the lack of shading elements contribute to the potential for PV at the site. A PV array located on the roof of the building may be feasible. If Montclair Community Pre-K is interested in pursuing the installation of PV, we recommended a full feasibility study be conducted.

Figure 25 - Photovoltaic Screening



Solar projects must register their projects in the SREC (Solar Renewable Energy Certificate) Registration Program (SRP) prior to the start of construction in order to establish the project’s eligibility to earn SRECs. Registration of the intent to participate in New Jersey's solar marketplace provides market participants with information about developed new solar projects and insight into future SREC pricing. Refer to Section 8.2 for additional information.

For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-fags>
- **Approved Solar Installers in the NJ Market:** http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

6.2 Combined Heat and Power

Combined heat and power (CHP) is the on-site generation of electricity along with the recovery of heat energy, which is put to beneficial use. Common technologies for CHP include reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines. Electric generation from a CHP system is typically interconnected to local power distribution systems. Heat is recovered from exhaust and ancillary cooling systems and interconnected to the existing hot water (or steam) distribution systems.

CHP systems are typically used to produce a portion of the electric power used onsite by a facility, with the balance of electric power needs supplied by grid purchases. The heat is used to supplement (or supplant) existing boilers for the purpose of space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for the purpose of space cooling. The key criteria used for screening, however, is the amount of time the system operates at full load and the facility's ability to use the recovered heat. Facilities with continuous use for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility does not have the potential for installing a cost-effective CHP system.

7 DEMAND RESPONSE

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically an electric customer needs to be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, in order to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (<http://www.pjm.com/markets-and-operations/demand-response/csps.aspx>). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (<http://www.pjm.com/training/training%20material.aspx>), along with a variety of other DR program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

In our opinion this building is not is a good candidate for DR.

8 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund your organization is eligible to participate in the LGEA program and also eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 26 for a list of the eligible programs identified for each recommended ECM.

Figure 26 - ECM Incentive Program Eligibility

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Direct Install	Pay For Performance Existing Buildings	Large Energy Users Program	Combined Heat & Power and Fuel Cell
ECM 1	Install LED Fixtures	x					
ECM 2	Retrofit Fixtures with LED Lamps	x					
ECM 3	Install Occupancy Sensor Lighting Controls	x					
ECM 4	Install High/Low Lighting Controls						

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. Direct Install caters to small to mid-size facilities that can bundle multiple ECMs together. This can greatly simplify participation and may lead to higher incentive amounts, but requires the use of pre-approved contractors. The Pay for Performance (P4P) program is a “whole-building” energy improvement program designed for larger facilities. It requires implementation of multiple measures meeting minimum savings thresholds, as well as use of pre-approved consultants. The Large Energy Users Program (LEUP) is available to New Jersey’s largest energy users giving them flexibility to install as little or as many measures, in a single facility or several facilities, with incentives capped based on the entity’s annual energy consumption. LEUP applicants can use in-house staff or a preferred contractor.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are located in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: www.njcleanenergy.com/ci.

8.1 SmartStart

Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

Equipment with Prescriptive Incentives Currently Available:

Electric Chillers

Electric Unitary HVAC

Gas Cooling

Gas Heating

Gas Water Heating

Ground Source Heat Pumps

Lighting

Lighting Controls

Refrigeration Doors

Refrigeration Controls

Refrigerator/Freezer Motors

Food Service Equipment

Variable Frequency Drives

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

How to Participate

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: www.njcleanenergy.com/SSB.

8.2 SREC Registration Program

The SREC (Solar Renewable Energy Certificate) Registration Program (SRP) is used to register the intent to install solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects MUST register their projects in the SRP prior to the start of construction in order to establish the project's eligibility to earn SRECs. Registration of the intent to participate in New Jersey's solar marketplace provides market participants with information about the pipeline of anticipated new solar capacity and insight into future SREC pricing.

After the registration is accepted, construction is complete, and final paperwork has been submitted and is deemed complete, the project is issued a New Jersey certification number which enables it to generate New Jersey SRECs. SREC's are generated once the solar project has been authorized to be energized by the Electric Distribution Company (EDC).

Each time a solar installation generates 1,000 kilowatt-hours (kWh) of electricity, an SREC is earned. Solar project owners report the energy production to the SREC Tracking System. This reporting allows SREC's to be placed in the customer's electronic account. SRECs can then be sold on the SREC Tracking System, providing revenue for the first 15 years of the project's life.

Electricity suppliers, the primary purchasers of SRECs, are required to pay a Solar Alternative Compliance Payment (SACP) if they do not meet the requirements of New Jersey's Solar RPS. One way they can meet the RPS requirements is by purchasing SRECs. As SRECs are traded in a competitive market, the price may vary significantly. The actual price of an SREC during a trading period can and will fluctuate depending on supply and demand.

Information about the SRP can be found at: www.njcleanenergy.com/srec.

8.3 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program descriptions and application can be found at: www.njcleanenergy.com/ESIP.

Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.

9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third-party (i.e. non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third-party supplier, consider shopping for a reduced rate from third-party electric suppliers. If your facility is purchasing electricity from a third-party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third-party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third-party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third-party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third-party supplier, consider shopping for a reduced rate from third-party natural gas suppliers. If your facility is purchasing natural gas from a third-party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third-party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

Appendix A: Equipment Inventory & Recommendations

Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Class 18	14	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,100	Relamp	Yes	14	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,470	0.50	1,839	0.0	\$280.35	\$1,862.80	\$315.00	5.52
Restroom 1	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.02	70	0.0	\$10.68	\$63.20	\$0.00	5.92
Restroom 2	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.02	70	0.0	\$10.68	\$63.20	\$0.00	5.92
Exec Dir Office	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	62	1,820	Relamp	No	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.17	553	0.0	\$84.24	\$468.00	\$80.00	4.61
Class 7	16	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,100	Relamp	Yes	16	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,470	0.66	2,417	0.0	\$368.46	\$2,013.20	\$345.00	4.53
Class 7	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.04	159	0.0	\$24.30	\$117.00	\$20.00	3.99
Restroom 1	2	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	2	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.04	140	0.0	\$21.35	\$126.40	\$0.00	5.92
Restroom 2	2	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	2	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.04	140	0.0	\$21.35	\$126.40	\$0.00	5.92
Closet	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.04	159	0.0	\$24.30	\$117.00	\$20.00	3.99
Stairwell 1	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.09	319	0.0	\$48.60	\$234.00	\$40.00	3.99
Stairwell 2	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.09	319	0.0	\$48.60	\$234.00	\$40.00	3.99
DLC Office	24	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,100	Relamp	Yes	24	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,470	0.98	3,625	0.0	\$552.69	\$2,884.80	\$500.00	4.31
DLC Office	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
DLC	21	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,100	Relamp	Yes	21	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,470	0.86	3,172	0.0	\$483.61	\$2,659.20	\$455.00	4.56
DLC	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Restroom 1	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.02	70	0.0	\$10.68	\$63.20	\$0.00	5.92
Restroom 2	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.02	70	0.0	\$10.68	\$63.20	\$0.00	5.92
Stairwell 1	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.06	239	0.0	\$36.45	\$175.50	\$30.00	3.99
Stairwell 2	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.06	239	0.0	\$36.45	\$175.50	\$30.00	3.99
LV1 1S Stairwell	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.06	239	0.0	\$36.45	\$175.50	\$30.00	3.99
LV1 1S Stairwell	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.06	239	0.0	\$36.45	\$175.50	\$30.00	3.99
Office	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Occupancy Sensor	93	1,820	Relamp	No	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.06	207	0.0	\$31.59	\$150.40	\$30.00	3.81
Hallway	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	Yes	6	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	1,470	0.16	604	0.0	\$92.12	\$551.00	\$60.00	5.33
Restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.02	80	0.0	\$12.15	\$58.50	\$10.00	3.99
Class 6	15	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Occupancy Sensor	93	1,820	Relamp	No	15	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.49	1,554	0.0	\$236.92	\$1,128.00	\$225.00	3.81

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Class 5	12	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Occupancy Sensor	93	1,820	Relamp	No	12	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.39	1,243	0.0	\$189.53	\$902.40	\$180.00	3.81
Restroom	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.02	70	0.0	\$10.68	\$63.20	\$0.00	5.92
Class 4	12	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Occupancy Sensor	93	1,820	Relamp	No	12	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.39	1,243	0.0	\$189.53	\$902.40	\$180.00	3.81
Stairwell 25	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.04	159	0.0	\$24.30	\$117.00	\$20.00	3.99
Stairwell 25	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Front Desk Area	12	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	Yes	12	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	1,470	0.31	1,127	0.0	\$171.86	\$1,298.40	\$70.00	7.15
Front Desk Area	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.02	80	0.0	\$12.15	\$58.50	\$10.00	3.99
Front Desk Area	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Nurse	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	62	1,820	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.13	414	0.0	\$63.18	\$351.00	\$60.00	4.61
Restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.02	80	0.0	\$12.15	\$58.50	\$10.00	3.99
Class 8	11	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,100	Relamp	Yes	11	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,470	0.45	1,662	0.0	\$253.32	\$1,367.20	\$235.00	4.47
Stairwell 3 Floor	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.13	478	0.0	\$72.90	\$351.00	\$60.00	3.99
3rd Floor Hall	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	1,470	0.11	403	0.0	\$61.41	\$434.00	\$40.00	6.42
3rd Floor Hall	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Class 16	7	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	Yes	7	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,470	0.19	705	0.0	\$107.47	\$679.50	\$105.00	5.35
Class 16	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.02	70	0.0	\$10.68	\$63.20	\$0.00	5.92
Class 16	3	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,100	Relamp	Yes	3	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,470	0.14	532	0.0	\$81.07	\$555.40	\$95.00	5.68
Office 1	3	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	114	1,820	Relamp	No	3	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,820	0.11	352	0.0	\$53.61	\$285.40	\$60.00	4.20
Office 2	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	114	1,820	Relamp	No	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,820	0.07	234	0.0	\$35.74	\$190.27	\$40.00	4.20
3rd Flr Stairwell Back	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	8	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.17	638	0.0	\$97.20	\$468.00	\$80.00	3.99
Class 15	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.02	70	0.0	\$10.68	\$63.20	\$0.00	5.92
Class 15	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,100	Relamp	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,470	0.58	2,127	0.0	\$324.28	\$1,681.60	\$310.00	4.23
Bathroom	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.02	70	0.0	\$10.68	\$63.20	\$0.00	5.92
Class 14	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.02	70	0.0	\$10.68	\$63.20	\$0.00	5.92
Class 14	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,100	Relamp	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,470	0.58	2,127	0.0	\$324.28	\$1,681.60	\$310.00	4.23

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Restroom 1	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.02	70	0.0	\$10.68	\$63.20	\$0.00	5.92
Restroom 2	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.02	70	0.0	\$10.68	\$63.20	\$0.00	5.92
Janitor Closet	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.02	70	0.0	\$10.68	\$63.20	\$0.00	5.92
2nd Fir Class 25	12	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,100	Relamp	Yes	12	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,470	0.49	1,813	0.0	\$276.35	\$1,442.40	\$250.00	4.31
Stairwell 2nd Fir	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.04	159	0.0	\$24.30	\$117.00	\$20.00	3.99
Hall 2nd Fir	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.04	159	0.0	\$24.30	\$117.00	\$20.00	3.99
Speech Therapy	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	62	1,820	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.04	138	0.0	\$21.06	\$117.00	\$20.00	4.61
Speech Therapy	3	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Occupancy Sensor	93	1,820	Relamp	No	3	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,820	0.10	311	0.0	\$47.38	\$225.60	\$45.00	3.81
Class 12/6	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,470	0.11	403	0.0	\$61.41	\$504.00	\$75.00	6.99
Class 12/6	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Class 12	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,470	0.11	403	0.0	\$61.41	\$504.00	\$75.00	6.99
Class 12	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Restroom 1	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,470	0.33	1,208	0.0	\$184.23	\$1,242.00	\$190.00	5.71
Restroom 1	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.02	70	0.0	\$10.68	\$63.20	\$0.00	5.92
Class 13	11	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,100	Relamp	Yes	11	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,470	0.45	1,662	0.0	\$253.32	\$1,367.20	\$235.00	4.47
Restroom 2	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.02	80	0.0	\$12.15	\$58.50	\$10.00	3.99
2nd Fir Stairwell	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.06	239	0.0	\$36.45	\$175.50	\$30.00	3.99
1st Fir Stairwell	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.09	319	0.0	\$48.60	\$234.00	\$40.00	3.99
2nd Fir N Hallway	16	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	16	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.35	1,275	0.0	\$194.39	\$936.00	\$160.00	3.99
2nd Fir N Hallway	4	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	4	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Restroom	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.02	70	0.0	\$10.68	\$63.20	\$0.00	5.92
Mop Closet	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.02	70	0.0	\$10.68	\$63.20	\$0.00	5.92
Stairwell/Back Door	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.04	159	0.0	\$24.30	\$117.00	\$20.00	3.99
Stairwell/Back Door	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,100	Relamp	No	2	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	2,100	0.06	239	0.0	\$36.45	\$150.40	\$30.00	3.30
Hallway (1st Fir)	6	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	Yes	6	LED - Linear Tubes: (2) U-Lamp	High/Low Control	33	1,470	0.15	564	0.0	\$85.93	\$579.20	\$0.00	6.74

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Hallway (1st Fir)	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Janitor Closet	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.02	70	0.0	\$10.68	\$63.20	\$0.00	5.92
Break Rm	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	62	1,820	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,820	0.09	276	0.0	\$42.12	\$234.00	\$40.00	4.61
Break Rm	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Occupancy Sensor	62	1,820	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	1,820	0.02	61	0.0	\$9.25	\$63.20	\$0.00	6.83
Restroom	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.02	70	0.0	\$10.68	\$63.20	\$0.00	5.92
Outer Class 2	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,470	0.08	302	0.0	\$46.06	\$715.50	\$100.00	13.36
Class 2	16	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,100	Relamp	Yes	16	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,470	0.66	2,417	0.0	\$368.46	\$2,013.20	\$345.00	4.53
Class 1	16	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,100	Relamp	Yes	16	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,470	0.66	2,417	0.0	\$368.46	\$2,013.20	\$345.00	4.53
Restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.02	80	0.0	\$12.15	\$58.50	\$10.00	3.99
Restroom	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	2,100	0.02	70	0.0	\$10.68	\$63.20	\$0.00	5.92
Pre-K Annex Rm 9	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,470	0.22	806	0.0	\$122.82	\$1,008.00	\$150.00	6.99
Pre-K Annex Rm 9	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Office	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.02	80	0.0	\$12.15	\$58.50	\$10.00	3.99
Restroom 1	1	Incandescent: INC-60W	Wall Switch	60	2,100	Relamp	No	1	LED Screw-In Lamps: LED-9W	Wall Switch	9	2,100	0.03	123	0.0	\$18.78	\$53.75	\$5.00	2.60
Restroom 2	1	Incandescent: INC-60W	Wall Switch	60	2,100	Relamp	No	1	LED Screw-In Lamps: LED-9W	Wall Switch	9	2,100	0.03	123	0.0	\$18.78	\$53.75	\$5.00	2.60
Annex Rm 8	15	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	Yes	15	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,470	0.41	1,511	0.0	\$230.29	\$1,687.50	\$255.00	6.22
Annex Rm 8	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Annex Rm 8	2	Incandescent: INC-60W	Wall Switch	60	2,100	Relamp	No	2	LED Screw-In Lamps: LED-9W	Wall Switch	9	2,100	0.07	246	0.0	\$37.55	\$107.51	\$10.00	2.60
Exterior Annex	2	Metal Halide: (1) 70W Lamp	Daylight Dimming	95	4,380	Fixture Replacement	No	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	29	4,380	0.09	670	0.0	\$102.13	\$781.35	\$200.00	5.69
Ext. Back of Pre-K Bldg	1	Metal Halide: (1) 100W Lamp	Daylight Dimming	128	4,380	Fixture Replacement	No	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	38	4,380	0.06	451	0.0	\$68.80	\$390.68	\$100.00	4.22
Elevator	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.02	80	0.0	\$12.15	\$58.50	\$10.00	3.99
Basement	25	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	Yes	25	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,470	0.68	2,518	0.0	\$383.82	\$2,542.50	\$390.00	5.61
Back stair	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,100	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,100	0.04	159	0.0	\$24.30	\$117.00	\$20.00	3.99
Ext Side Bldg	4	High-Pressure Sodium: (1) 150W Lamp	Daylight Dimming	188	4,380	Fixture Replacement	No	4	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	56	4,380	0.35	2,651	0.0	\$404.22	\$1,562.71	\$400.00	2.88
Ext Front Entrance	1	High-Pressure Sodium: (1) 150W Lamp	Daylight Dimming	188	4,380	Fixture Replacement	No	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Daylight Dimming	56	4,380	0.09	663	0.0	\$101.05	\$390.68	\$100.00	2.88

Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions										Energy Impact & Financial Analysis						
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Room 1	Room 1	1	Window AC	1.25		Yes	1	Window AC	1.25		12.00		No	0.08	114	0.0	\$17.31	\$1,360.95	\$0.00	78.63
2	2	1	Window AC	1.25		Yes	1	Window AC	1.25		12.00		No	0.08	114	0.0	\$17.31	\$1,360.95	\$0.00	78.63
2 Office	2 Office	1	Window AC	0.67		Yes	1	Window AC	0.67		12.00		No	0.05	61	0.0	\$9.23	\$725.84	\$0.00	78.63
3	3	1	Packaged AC	1.00		Yes	1	Packaged AC	1.00		14.00		No	0.16	219	0.0	\$33.45	\$2,268.96	\$92.00	65.09
4	4	1	Window AC	0.58		Yes	1	Window AC	0.58		12.00		No	0.04	53	0.0	\$8.08	\$635.11	\$0.00	78.63
4	4	1	Window AC	0.83		Yes	1	Window AC	0.83		12.00		No	0.06	76	0.0	\$11.54	\$907.30	\$0.00	78.63
5	5	1	Window AC	1.00		Yes	1	Window AC	1.00		12.00		No	0.07	91	0.0	\$13.85	\$1,088.76	\$0.00	78.63
5	5	1	Window AC	1.00		Yes	1	Window AC	1.00		12.00		No	0.07	91	0.0	\$13.85	\$1,088.76	\$0.00	78.63
6	6	1	Window AC	1.25		Yes	1	Window AC	1.25		12.00		No	0.08	114	0.0	\$17.31	\$1,360.95	\$0.00	78.63
6	6	1	Window AC	1.00		Yes	1	Window AC	1.00		12.00		No	0.07	91	0.0	\$13.85	\$1,088.76	\$0.00	78.63
7	7	1	Window AC	0.83		Yes	1	Window AC	0.83		12.00		No	0.06	76	0.0	\$11.54	\$907.30	\$0.00	78.63
8 A-B	8 A-B	1	Window AC	1.00		Yes	1	Window AC	1.00		12.00		No	0.07	91	0.0	\$13.85	\$1,088.76	\$0.00	78.63
8 A-B	8 A-B	1	Window AC	1.00		Yes	1	Window AC	1.00		12.00		No	0.07	91	0.0	\$13.85	\$1,088.76	\$0.00	78.63
10	10	1	Packaged AC	1.00		Yes	1	Packaged AC	1.00		14.00		No	0.16	219	0.0	\$33.45	\$2,268.96	\$92.00	65.09
11	11	1	Window AC	0.83		Yes	1	Window AC	0.83		12.00		No	0.06	76	0.0	\$11.54	\$907.30	\$0.00	78.63
12	12	1	Window AC	0.83		Yes	1	Window AC	0.83		12.00		No	0.06	76	0.0	\$11.54	\$907.30	\$0.00	78.63
14	14	1	Window AC	1.00		Yes	1	Window AC	1.00		12.00		No	0.07	91	0.0	\$13.85	\$1,088.76	\$0.00	78.63
15	15	1	Window AC	1.00		Yes	1	Window AC	1.00		12.00		No	0.07	91	0.0	\$13.85	\$1,088.76	\$0.00	78.63
Child Study	Child Study	1	Window AC	1.00		Yes	1	Window AC	1.00		12.00		No	0.07	91	0.0	\$13.85	\$1,088.76	\$0.00	78.63
DLC Office	DLC Office	1	Window AC	1.00		Yes	1	Window AC	1.00		12.00		No	0.07	91	0.0	\$13.85	\$1,088.76	\$0.00	78.63

		Existing Conditions				Proposed Conditions						Energy Impact & Financial Analysis								
Location	Area(s)/System(s) Served	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
DLC Office	DLC Office	1	Window AC	1.00		Yes	1	Window AC	1.00		12.00		No	0.07	91	0.0	\$13.85	\$1,088.76	\$0.00	78.63
DLC Office	DLC Office	1	Window AC	0.83		Yes	1	Window AC	0.83		12.00		No	0.06	76	0.0	\$11.54	\$907.30	\$0.00	78.63
Rooftop Unit	Rooftop Unit	1	Packaged AC	1.00		Yes	1	Packaged AC	1.00		14.00		No	0.16	219	0.0	\$33.45	\$2,268.96	\$92.00	65.09
Rooftop Unit	Rooftop Unit	1	Packaged AC	2.50		Yes	1	Packaged AC	2.50		14.00		No	0.41	548	0.0	\$83.62	\$5,672.40	\$230.00	65.09
Rooftop Unit #1 A/C	Rooftop Unit #1 A/C	1	Packaged AC	2.67		Yes	1	Packaged AC	2.67		14.00		No	0.44	585	0.0	\$89.19	\$6,050.56	\$245.33	65.09
Rooftop Unit #2 A/C	Rooftop Unit #2 A/C	1	Packaged AC	2.67		Yes	1	Packaged AC	2.67		14.00		No	0.44	585	0.0	\$89.19	\$6,050.56	\$245.33	65.09
Speech Rm	Speech Rm	1	Window AC	1.00		Yes	1	Window AC	1.00		12.00		No	0.07	91	0.0	\$13.85	\$1,088.76	\$0.00	78.63

Fuel Heating Inventory & Recommendations

		Existing Conditions			Proposed Conditions						Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	System Quantity	System Type	Output Capacity per Unit (MBh)	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Central Plant	Central Plant	1	Forced Draft Steam Boiler	500.00	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00


DHW Inventory & Recommendations

		Existing Conditions			Proposed Conditions						Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
Mechanical Room	Comm. Pre-K	1	Storage Tank Water Heater (> 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00	

Plug Load Inventory

Existing Conditions				
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
Pre-K	2	Small Printer	20.0	No
Pre-K	1	Small Copier	20.0	No
Pre-K	3	Microwave	1,000.0	No
Pre-K	2	Large Copier	515.0	No
Pre-K	3	Refrigerator	50.0	No

Appendix B: ENERGY STAR® Statement of Energy Performance



ENERGY STAR® Statement of Energy Performance

LEARN MORE AT energystar.gov

74

ENERGY STAR®
Score¹

Montclair Valley Road Campus (4 Buildings)

Primary Property Type: K-12 School

Gross Floor Area (ft²): 172,102

Built: 1879

For Year Ending: April 30, 2016

Date Generated: June 20, 2018

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information		
Property Address Montclair Valley Road Campus (4 Buildings) 22 Valley Road Montclair, New Jersey 07042	Property Owner Montclair Board of Education 22 Valley Road Montclair, NJ 07042 (973) 509-4050	Primary Contact Steve DiGeronimo 22 Valley Road Montclair, NJ 07042 (973) 509-4050 bfeischer@montclair.k12.nj.us
Property ID: 6364554		

Energy Consumption and Energy Use Intensity (EUI)			
Site EUI 47.1 kBtu/ft²	Annual Energy by Fuel		National Median Comparison
	Natural Gas (kBtu)	5,917,390 (73%)	National Median Site EUI (kBtu/ft²) 60.1
	Electric - Grid (kBtu)	2,187,666 (27%)	National Median Source EUI (kBtu/ft²) 97
			% Diff from National Median Source EUI -22%
Source EUI 76 kBtu/ft²			Annual Emissions
			Greenhouse Gas Emissions (Metric Tons CO2e/year) 557


Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional

() _____



Professional Engineer Stamp
(if applicable)